

Certificate of Compliance

Certificate Number 20080320-E163022
Report Reference E163022, 2008 March 18
Issue Date 2008 March 20

Page 1 of 2



Issued to: **MAC3 SPA**
VIA BALDANZESE 149,
50041 CALENZANO FI, ITALY


This is to certify that representative samples of **FLOAT-AND PRESSURE-OPERATED MOTOR CONTROLLERS**
Recognized Float-Operated Switch, Model AG0UL

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508 - 17th Edition, Industrial Control Equipment.

Additional Information: See Addendum for Ratings.

Only those products bearing the UL Recognized Component Marking should be considered as being covered by UL's Recognition and Follow-Up Service.

The UL Recognized Component Marking generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

Look for the UL Recognized Component Marking on the product

Issued By:
Giorgio Puglia, Engineer
Underwriters Laboratories Inc.

Reviewed By:
Matteo Redaelli, Group Leader Engineer
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20080320-E163022**
Report Reference **E163022, 2008 March 18**
Issue Date **2008 March 20**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

HP	V	A	Hz
2Hp	250Vac	-	50-60
1Hp	125Vac	-	50-60
-	250Vac	16A	50-60

Operating Ambient Temperature: 0-50°C

Issued By:
Giorgio Puglia, Engineer
Underwriters Laboratories Inc.

Reviewed By:
Matteo Redaelli, Group Leader Engineer
Underwriters Laboratories Inc.